



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE**



From
The Director General
State Disaster Response and Fire Services,
Telangana, Hyderabad.

To,
SAHAJ MARG SPIRITUALITY FOUNDATION,
Khana Shanti Vanam ,
13-110,
Khana Village,
Nandigama Mandal,
Ranga Reddy District,
Telangana ,

Rc. No.236710002019Dated:20/01/2020

Sir,

Sub: TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –
Issue of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **SCHOOL BUILDING,SCHOOL BUILDING IN** Survey nos :112/Part, situated at Chegur Village, Nandigama Mandal, Shadnagar revenue division, Ranga Reddy dist., (Erstwhile Kothur Mandal, Mahboobnagar district) Telangana State.FULL SURVEY NOs.:112/42; 112/43; 112/44;112/46 ; 112/47 ; 112/48; 112/49;112/50; 112/51; 112/52 ; 112/53; 112/54; 112/55; 112/61;112/62; 112/63 ; 112/64;. 112/65; 112/66; 112/67;112/68; 112/71; 112/72; 112/73; 112/85; 112/91; 112/92 ; 112/93; 112/94;112/95. PART SURVEY NOs. : 111/A; 112/39; 112/40; 112/41;112/45; 112/56;112/57; 112/58; 112/59;112/60;112/69; 112/70; 112/74; 112/75; 112/86; 112/96;112/98; 112/110;112/166; /- Nandigama/Nandigama/Rangareddy, Hyderabad – Regarding.



Ref: 1. Acknowledgement N6236710002019dt.20/01/2020
2. Inspection Committee Report, Acknowledgement No: 236710002019

1. The Multi Storeyed Building Inspection committee, vide reference cited (2) have inspected the Non Multi Storeyed Building of **SCHOOL BUILDING,SCHOOL BUILDING IN** Survey nos :112/Part, situated at Chegur Village, Nandigama Mandal, Shadnagar revenue division, Ranga Reddy dist., (Erstwhile Kothur Mandal, Mahboobnagar district) Telangana State.FULL SURVEY NOs.:112/42; 112/43; 112/44;112/46 ; 112/47 ; 112/48; 112/49;112/50; 112/51; 112/52 ; 112/53; 112/54; 112/55; 112/61;112/62; 112/63 ; 112/64;. 112/65; 112/66; 112/67;112/68; 112/71; 112/72; 112/73; 112/85; 112/91; 112/92 ; 112/93; 112/94;112/95. PART SURVEY NOs. : 111/A; 112/39; 112/40; 112/41;112/45; 112/56;112/57; 112/58; 112/59;112/60;112/69; 112/70; 112/74; 112/75; 112/86; 112/96;112/98; 112/110;112/166; /-Nandigama/Nandigama/Rangareddy and submitted the following report.

2.The above building was constructed without obtaining the Provisional Noc from this department and now the builder submitted application for issuance of No Objection Certificate for occupancy to the existing bulding of **Ground, 2 Floors**, with a height of **11.20 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level**.

3. Open Spaces : The builder provided the following open spaces all around the building.

Sl.No	side	Open space Required as per Supreme Court's order on W.P.No.483 of 2004	Open space Provided
1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
5	Front Direction	North	

4. Means of Access :

Sl. No	Gate Width As per NBC 2016	Required	Provided
--------	----------------------------	----------	----------

1	Entry gate width	6.00	6.00
2	Exit Gate Width	6.00	6.00
3	Entry Gate Head Clearance	4.50	5.00
4	Exit Gate Head Clearance	4.50	5.00

5. Travel Distance

Sl. No.	Item / Description	Required (Not More than in Mtrs.)	Provided
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	29.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	5.50

6. Stair Cases (As per NBC 2016)

Sl.no.	Type of staircases	Width (In Mtrs)	No of staircases	Floors from	Floors to
1	Internal staircases	1.80	2	Ground	Terrace
2	External staircases	1.85	1	Ground	Terrace
3	External staircases	2.00	1	Ground	Terrace
4	External staircases	2.00	1	Ground	Terrace

7. Means of Escape Floor Wise Details

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per table 21 of NBC	Means of escape Provided
1	Ground	3499.00	EDUCATIONAL B-1 Schools up to senior secondary level	875.00	8.75	12.00
2	1st Floor	3499.00	EDUCATIONAL B-1 Schools up to senior secondary level	875.00	8.75	9.45
3	2nd Floor	3389.00	EDUCATIONAL B-1 Schools up to senior secondary level	847.00	8.47	9.45

8. Floor Wise details of Fire Fighting Installations.

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	18.00	4.00	0.00	0.00	0.00
2	1st Floor	18.00	4.00	0.00	0.00	0.00
3	2nd Floor	17.00	4.00	0.00	0.00	0.00

9. Fire Fighting Installations as per Table 7 of NBC 2016:

Fire Fighting System.	Required As per NBC	Provided
Fire Extinguishers	53.00	60
First Aid Hose Reel	12.00	12
Terrace Tank over Respective Tower Terrace in Litres	10000.00	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	450.00	900

10. The builder has provided the following additional Fire Safety Requirements as per NBC of India 2016 as per NBC part 4 of India 2016::

Sl. No	Fire safety Item
1.	Open spaces all around the building are Leveled and have hard open spaces for the operation of fire vehicles.
2.	The upper floors of the educational building are provided with exits for every travel distance of 30 meters (TYPE1 & 2 constructions) as per table5 under clause 4.4.2.1, 4.4.2.2 of Part IV of NBC 2016

3. The width of all exit door ways has 01-00 meter for class rooms and 02-00 meters in respect of Assembly halls as per clause 8.1 of IS 14435:1997?
4. The height of exit door ways has 02-00 meters and more, as per clause of 8.2 of IS 14435:1997?
5. A minimum number of two separate exits are provided for each floor as per clause 6.2 of IS 14435:1997?
6. The exits shall be remote from each other as practicable as per clause 6.2 of IS 14435:1997?
7. 02 Doorways are provided for every room with a capacity of over 45 persons As per clause 6.2.2(a) of part-IV of NBC-2016
8. The Location of Rooms of Preschool, Kindergarten, Class/Grade I student are provided at Ground Floor/level and Class/Grade II student at ground or First Floor only.
12. **Electrical safety complied with as per Clause 3.4.6 of part – 4 NBC of India 2016**
d) all metallic items like steel structural members, etc, shall be bonded properly to the earthing system.
15. **Lighting is Complied with as per Clause – 3.4.7.1**
a) The exit, exit access and exit discharge systems shall be illuminated continuously. The floors of the means of egress shall be illuminated at all points, including angles and intersections, in corridors and passageways, stairwells, landings of stairwells and exit.
b) Emergency lighting shall be powered from a source independent of that supplying the normal lighting.
c) The emergency lighting shall be provided to be put on within 5 s of the failure of the normal lighting supply. Also, emergency lighting shall be able to maintain the required illumination level for a period of not less than 90 min in the event of failure of the normal lighting even for smaller premises.
d) Signs are required at all exits, emergency exits and escape routes, which should comply with the graphic requirements of the relevant Indian Standards
16. Exit passageway (at ground) and staircase lighting is connected to alternative supply. The alternative source of supply may be provided by battery continuously trickle charged from the electric mains as per clause – 3.4.7.2
17. Number of exits, Arrangements of exits and capacities of Means of egress types of exit access and exits etc., complied with Clause 4.4.2 of part – 4 NBC of India 2016
18. Smoke control of exits are complied with Clause 4.4 2.5of part – 4 NBC of India 2016
Fire Drills and Fire orders Complied with Clause 4.11 of part – 4 NBC of India 2016
Fire notices/orders shall be prepared to fulfil the requirements of firefighting and evacuation from the buildings in the event of fire and other emergency. The occupants shall be made thoroughly conversant with their action in the event of emergency, by displaying fire notices at vantage points and also through regular training. Such notices should be displayed prominently in bold lettering. For guidelines for fire drills and evacuation procedures for high rise buildings, see Annex D
20. Fire extinguishers / fixed fire fighting installations, static water storage tanks and pump house are Complied with Clause 5.1 of part – 4 NBC of India 2016
22. Fire Safety plans prepared and submitted by the builder.
23. Fire Drills shall be conducted with accordance with the fire safety plan at least once in every 03 months for building during the first 02 Years and there after once in 6 months as per Clause D-3 in annex. D of Part IV NBC of India 2016.

11) In view of the above and as per recommendations of the multistoried building inspection Committee, the No Objection Certificate for occupancy is issued to Multi Storied Building with

Sl No	As Builder	As occupant	As Security Personnel
1	-All the fire protection arrangements shall be maintained in good condition as seen during inspection. -Do's and Don't in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall	All occupants shall be trained to operate the fire safety equipments during	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

	be the responsibility of the management.	emergency.	
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If Not, take all steps to isolate the area by closing doors and windows.

This No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
 Director General of State Disaster
 Response & Fire Services
 Telangana, Hyderabad

Copies to:

- i) The Management
- ii) Multistoried Building Inspection Committee